



ORDINANCE NO. 1096

AN ORDINANCE AMENDING ORINANCE 1063 ADOPTING THE INTERNATIONAL FIRE CODE, 2009 EDITION, COPYRIGHTED BY THE INTERNATIONAL CODE COUNCIL; REQUIRING COPIES OF SAID CODE TO BE KEPT IN THE OFFICE OF THE CITY CLERK; PROVIDING FOR A PENALTY FOR THE VIOLATION OF THIS ORDINANCE AND FOR SEVERABILITY; AND PROVIDING WHEN THIS ORDINANCE SHALL BECOME EFFECTIVE.

BE IT ORDAINED BY THE MAYOR AND COUNCIL OF THE CITY OF REXBURG, IDAHO;

SECTION I: That the document known as the International Fire Code (IFC), 2009 Edition, is hereby adopted as the fire code for the City of Rexburg, Idaho as amended.

SECTION II: Additionally, the 2009 International Fire Code is amended and changed in the following respects:

MM. 903.1.3 Freeze protection. Approved automatic sprinkler systems in new buildings and structures shall be protected from freezing to a temperature of -40° Fahrenheit.

OO. 903.3.7 Fire department connections. The location of fire department connections (FDC) shall be within 150 feet of a hydrant and adjacent to the fire apparatus access road. The FDC shall include clappers.

PP. 903.3.8 Approved piping. All piping and fittings four inches or greater shall be ductile iron beginning at a minimum of three feet from the exterior of the building or structure and continuing through to the appurtenances associated with the fire suppression system. Private fire service mains and their appurtenances shall be tested in accordance to NFPA 24.

RR. 906.5 Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. R-2 occupancies shall have at a minimum one portable fire extinguisher within the dwelling unit located near the cooking area. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

UU. 907.7.3.2.3 Zone and address location labeling. Fire alarm control panels (FACP) shall have all zones and address points plainly and permanently labeled as to their location, on the outside of the panel or on an easily readable map of the building affixed to the outside of the panel. The access doors leading to the FACP shall be posted with "FACP" in four inch tall letters with $\frac{1}{2}$ " stroke width.

WW. B105.3 Hydrant testing. Fire flow testing of hydrants shall be supervised by the fire code official. Documentation of the hydrant testing shall be made available to the fire code official within 10 working days.

ZZ. D105.3 Proximity to building. Buildings or structures of four stories or less shall have at least one of the required access routes located within a minimum of 15 feet and maximum of 45 feet from the building, and shall be positioned parallel to one entire side of the building. Buildings or structures greater than four stories shall have at least one of the required access routes located within a minimum of 15 feet and

maximum of 30 feet from the building, and shall be positioned parallel to one entire side of the building.

Section III: There has been on file and there shall hereafter be kept on file, in the office of the City Clerk one (1) copy of said International Fire Code, 2009 edition, duly certified by the clerk, for use and examination by the public.

Section IV: The sections of this Ordinance are severable and the invalidity of a section shall not affect the validity of the remaining sections.

Section V: All ordinances or parts of ordinances in conflict herewith are hereby repealed.

Section VI: This Ordinance shall become effective upon its passage, approval and publication in the manner provided by law this 22nd day of December, 2012.

PASSED BY THE COUNCIL AND APPROVED BY THE MAYOR this 19th day of December, 2012.

Richard Woodland, Mayor

ATTEST:

Blair D. Kay, City Clerk

(SEAL)

STATE OF IDAHO)
County of Madison: ss)
City of Rexburg)

I, BLAIR D. KAY, City Clerk of the city of Rexburg, Idaho, do hereby certify:
That the above and foregoing is a full, true and correct copy of the Ordinance Entitled:

AN ORDINANCE AMENDING ORINANCE 1063 ADOPTING THE INTERNATIONAL FIRE CODE, 2009 EDITION, COPYRIGHTED BY THE INTERNATIONAL CODE COUNCIL; REQUIRING COPIES OF SAID CODE TO BE KEPT IN THE OFFICE OF THE CITY CLERK; PROVIDING FOR A PENALTY FOR THE VIOLATION OF THIS ORDINANCE AND FOR SEVERABILITY; AND PROVIDING WHEN THIS ORDINANCE SHALL BECOME EFFECTIVE.

Passed by the City Council and approved by the Mayor this 19th day of December, 2012.

Blair D. Kay, City Clerk

(SEAL)